

This register is **NOT sealed to drywall.**



To Fix: Apply caulk or polyisobutylene backed UL181 approved metal backed tape from drywall to sheet metal.